

Certificate of Conformity

This is to certify that:

Transdelta Industries SPC
PO Box 75, Sohar
North Al Batinah Governate
ZIP CODE 314
314
Oman

Holds Certificate Number:

CNF 805946

In respect of:

BS EN IEC 61386-23:2021+A11:2021 Conduit systems for cable management: Flexible conduit systems



For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2025-11-04

Effective Date: 2025-11-04

Latest Issue: 2025-11-04

Expiry Date: 2028-11-03

Page: 1 of 2



Certificate of Conformity

No. CNF 805946

Type test report number: 23-2721-R0-N1, 23-2721-R0-N2 & 23-2721-R0-N3 – LVT

Product description

BS EN 61386-23:2004+A11:2021 for flexible conduit systems

Products Verified:

Product Description	Size	Classification/Identification Number (Mechanical Strength)	IP Rating	Operating Temperature	Flame Protection
Corrugated steel flexible conduit with PVC jacket	20mm & 25mm	2342X	IP54	-25 °C 105 °C	Non-flame propagating
Liquid Tight Corrugated steel flexible conduit with PVC jacket	20mm & 25mm	2342X	IP67	-25 °C 105 °C	Non-flame propagating
Corrugated steel flexible conduit with PE + low smoke zero halogen jacket	20mm & 25mm	2342X	IP54	-25 °C 90 °C	Non-flame propagating

First Issued: 2025-11-04

Latest Issue: 2025-11-04

Effective Date: 2025-11-04

Expiry Date: 2028-11-03

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at Seventh and Eighth Floors, The Acre, 90 Long Acre, London, WC2E 9RA, UK.
A member of BSI Group of Companies.